



established 1823

CLARKESVILLE

— We Call it Home. —

New Business Check List

- ☐ Business License Application/ Mandatory Affidavit Verifying Status for City Public Benefit Application
- ☐ Certificate of Occupancy Inspection/Courtesy Pre-Fire Plan (Zoning Administration/Building Inspector/Fire Dept.). *Must be complete before Business license is issued.*
- ☐ Read Clarkesville Fire Prevention Ordinance before any building alterations (including adding partitions).
- ☐ Sign Permit Application & Regulations (Zoning Administration/Building Inspector). **Any signs installed before approval will be subject to double permit fees and/or removal.**
- ☐ Water/Sanitation Service/Information Sheet (City Hall)
- ☐ Garbage Service Waiver (if using 3rd Party provider). Submit to City Hall.
- ☐ Open for Business Resource publication – Clarkesville Mainstreet
- ☐ Alcohol License – See City Clerk 706-754-4216
- ☐ State of Georgia Professional License (if needed)
- ☐ Schedule Health Department Inspection (if needed) – Health Dept.

Please check all items pertaining to your business and return checklist to City Clerk before scheduling Certificate of Occupancy Inspection.


I acknowledge that I have read and understand the above items.

Printed Name: _____ Date: _____

Signature: _____

Resources can also be found online @ <http://www.clarkesvillega.com/planning-and-zoning.cfm>

A Gentle-Friendly Place



established 1823

CLARKESVILLE

— We Call it Home. —

Certificate of Occupancy/Pre-Fire Plan Check List:

It is suggested when scheduling an inspection; the business should be setup as if ready to open to the public. One to two weeks is a good time frame for correcting any items before public opening.

These are a few common items that are looked for, but not limited to, when inspections are being conducted:

- Building structure
- **Fire Safety**
 - **Fire Extinguishers tagged (inspected), mounted and marked with signage. 1 – 10lb per 3,000 square feet.**
 - **Exit signage mounted and tested. Emergency Lighting and/or combo/Exit lights where needed.**
 - **Minimum three (3) foot clearance between aisles.**
 - **Egress (Exit) doors clear and unobstructed and unlocked during business hours.**
- Electrical
 - No open grounds or other electrical wiring problems
 - Panel box labeled and covered properly
 - 36" Clearance around panel box
- Mechanical
 - 36" Clearance around mechanical equipment & accessible
- Plumbing
 - 36" Clearance around hot water heater & accessible
- Storage areas
 - Storage of flammable/hazardous materials prohibited in all storage areas in public buildings.

If there are any repairs that involve permitted work, please contact City of Clarkesville building department.

A Gentle-Friendly Place